

Clack®

WS1.25TC

WATER SPECIALIST CONTROL VALVE



shown with optional bypass



Certified to NSF/ANSI 44 and NSF/ANSI/CAN 61 and 372.

- More informative 4 digit LCD Display with Status Indicators
- Solid state microprocessor with easy access front panel settings
- Service flow rate of 34 gpm, backwash 32 gpm
- Backwash and brining ability to 21" diameter tanks
- Front panel display for time of day, days until next regeneration
- Days between regeneration feature: 1-99 days standard; 7-day optional
- Double backwash feature offers optimum regeneration, cleaning ability and efficiency
- 10 selectable pre-programmed regeneration cycles
- Coin Cell Lithium battery back-up with a 8 hour carry over
- Auto detection of 50/60 Hz line frequency, with automatic 12/24 hour time keeping formats
- Level VI 15-volt output DC power supply provides safe and easy installation
- Patented one piece expanding seal spacer stack assembly
- Patented linearly reciprocating piston operation
- Post treated water regenerant refill
- Reliable and proven DC drive

Water Specialist 1.25" TC Control Specifications

Inlet/Outlet Fittings.....	¾" to 1.5" NPS
Cycles	up to 6
Valve Material	Fiber Reinforced Composite
Regeneration	Downflow

FLOW RATES

Service @15 psi drop (includes bypass and 1.25" fitting kit).....	34 gpm
Backwash @ 25 psi drop	32 gpm (1)
Cv Service	8.8
Cv Backwash	6.4

OPERATING PRESSURES

Minimum/Maximum	20 psi – 125 psi
-----------------------	------------------

OPERATING TEMPERATURES

Minimum/Maximum	40° – 110° F
-----------------------	--------------

DIMENSIONS & WEIGHT

Distributor Pilot.....	1.32" OD Pipe (1" NPS) or 32mm OD
Drain Line	¾" or 1" NPT
Brine Line	¾" or ½" OD Poly Tube
Mounting Base.....	2 ½" - 8 NPSM
Height From Top Of Tank.....	7 ¾"
Weight	4.5 lbs.

ELECTRICAL SPECIFICATIONS

POWER SUPPLY

	<u>U.S.</u>	<u>International</u>
Supply Voltage	100VAC to 120VAC.....	200VAC to 240VAC
Supply Frequency	50/60 Hz.....	50/60 Hz
Output Voltage	15VDC.....	15VDC
Output Current	500 mA.....	500 mA

TANK APPLICATIONS

Water Softener	6" – 21" diameter
Water Filter (2).....	6" – 24" diameter

CYCLES OF OPERATION (Softener Downflow)

Cycle	Range of times minutes
1. Backwash 1 st (upflow).....	3 - 12
2. Regenerate Draw/Slow Rinse (downflow)	50 - 70
3. Backwash 2 nd (upflow)	3 - 12
4. Fast Rinse (downflow)	3 - 8
5. Regenerant Refill (in service with treated water).....	As Programmed
6. Service (downflow)	

Options: Backwash Filter, Bypass, Weather Cover

Compatible with the following typical concentration of regenerants or chemicals: Sodium chloride, potassium chloride, potassium permanganate, sodium bisulfite, chlorine and chloramines

1. Acquired by use of external drain line flow control
2. Filter tank size calculated @ 10 gpm of backwash per square foot of bed area