





Membrane Element


SWC6-LD (Low Fouling Technology)

Performance:	Permeate Flow: Salt Rejection: Boron Rejection (Typical) [†] : Applied Pressure:	Low Pressure: 6,000 gpd (22.7 m ³ /d) 99.6% (99.4 % min) 83.0% 600 psi (4.1 MPa)	High Flow: 12,000 gpd (45.5 m3/d) 99.8 % (99.7 % min) 91.0% 800 psi (5.4 MPa)		
Туре	Configuration: Membrane Polymer: Membrane Active Area: Feed Spacer:	Spiral Wound Composite Polyamide 400 ft ² (37.2m ²) 34 mil (0.864 mm) with biostatic agent			
Application Data*	Maximum Applied Pressure: Maximum Chlorine Concentration: Maximum Operating Temperature: pH Range, Continuous (Cleaning): Maximum Feedwater Turbidity: Maximum Feedwater SDI (15 mins): Maximum Feed Flow: Minimum Ratio of Concentrate to Permeate Flow for any Element: Maximum Pressure Drop for Each Element:				

* The limitations shown here are for general use. For specific projects, operating at more conservative values may ensure the best performance and longest life of the membrane. See Hydranautics Technical Bulletins for more detail on operation limits, cleaning pH, and cleaning temperatures.

Test Conditions

The stated performance is initial (data taken after 30 minutes of operation), based on the following low pressure conditions:



		40.0	(1016)	7.89	(200)	1.125	(28.6)	33	(15)	
Notice:	Permeate flow for individuate	al elements	may vary +25	i% or -15%.	Membrane a	active area ma	ay vary +/-4%	5. Element weig	ght may vary.	All membrane elements are
supplied with a brine seal, interconnector, and o-rings. Elements are enclosed in a sealed polyethylene bag containing less than 1.0% sodium meta-bisulfite solution, and then										
nackaged i	n a cardhoard box									

packaged in a cardboard box. ¹When tested at standard test conditions with 5.0 ppm Boron in feed solution.

Hydranautics believes the information and data contained herein to be accurate and useful. The information and data are offered in good faith, but without guarantee, as right and the set of t presented information and data. It is the user's responsibility to determine the appropriateness of Hydranautics' products for the user's specific end uses 3/06/15